

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

W.F. Taylor Co., Inc.

800 College Dr., Dalton, CA, United States

For the following product(s):

Flooring Adhesives:

WF Taylor Adhesives 2027, 2033, 2037, 2040, 2071, 2082, 2083, 2084, 2087, 2090, 2091, 2098, Agile, Dynamic, Enviro Poxy 501, Finale, MS Bond-N-Weld, MS Plus Advance, MS Plus Resilient MBA, Pinnacle, PS 580, Redi-Set, Resolute and SoundLevel, RidgeLine and IronWood, Sahara, Steadfast, VersaTile, Zephyr

The product(s) meets all of the necessary qualifications to be certified for the following claim:

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom, private office, and single-family residence parameters when modeled as Flooring. Also, conforms to the SCAQMD Rule 1168 - Adhesive and Sealants (January 2005).

Standard Product Application Amount: 612.8 g/m²

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³; (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Methylene Chloride and Perchloroethylene are not intentionally added to certified products.

Registration # SCS-FS-03175

Valid from: October 1, 2018 to September 30, 2019

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ISO/IEC 17065
Product Certification Body
#0821



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA